

Annexure C

SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. DSO/WSCC/26-27/0004

Dated: 08/05/2026

It is certified that an inspection team headed by Dr. Ramit Kumar Singh, DSO

(Name of Officers with designation) from CMO Office, Bulandshahr, U.P. 203001 Public Health

Department inspected the **NIRMALA CONVENT SCHOOL, SHIKARPUR BYPASS ROAD,**

BULANDSHAHR, U.P. 203001 (Name & Address of the school) on 8/5/2026 (date

of inspection) and on the basis of Water Test Report (Attached) bearing

no. T-9249 dated 8/5/26 of U.P. Water corporation (Rural)

Bulandshahr certified that the **NIRMALA CONVENT SCHOOL, SHIKARPUR BYPASS**

ROAD, BULANDSHAHR, U.P. 203001 (Name of school) has safe drinking water facilities for

the students and members of staff of the institution. School is also maintains the hygienic

sanitation condition in the school building & the campus as per norms prescribed by the

Central/ State/ U.T. Govt.

This certificate is valid till 7/5/2027

Signature with Seal: 

Name

Dr. Ramit Kumar Singh

Designation

DSO, Public Health Department, Bulandshahr

Name & Address of the Office / Department:

CMO Office, Bulandshahr

To

**NIRMALA CONVENT SCHOOL
SHIKARPUR BYPASS ROAD
BULANDSHAHR, U.P. 203001**

Note: The certificate is to be issued by authorized officer / PHED Lab / local bodies


(Principal)
Nirmala Convent School
Shikarpur By Pass Road
Bulandshahr (U.P.) 203001

Mana
MANAGER
NIRMALA CONVENT SCHOOL
SHIKARPUR BYE PASS ROAD
BULANDSHAHR (U.P.)



District Level Water Analysis Laboratory UP Jal Nigam (Rural), Bulandshahr

TEST REPORT

UTR NO:	: T 9249	Issue Date	08/05/2026
Sample receipt Date:	: 07/05/2026	Expired Date	08/11/2026
Customer/Party Name	: NIRMALA CONVENT SCHOOL		
Address	: Shikarpur Bye Pass Road, Bulandshahr, UP 203001		
Contact No.	: 9458222002		
Date of Sampling	: 07/05/2026	Sample Code: B 101	
Sample Description	: 07/05/2026	Quantity of Sample	1000ML
Quantity*	: 1	Water Source	SAMAR SEVAL WATER
Packing details	:	Sampling Method	As per IS 17614:Part-2021
Analysis Start	: 07/05/2026	Analysis Completion Date	08/05/2026
Temperature	: 26.1°C	Humidity	54%
Water Sample Provided ByAnuj Sharma			
Availability of Equipments:		Availability of reference standards:	
Availability of Test method:	IS 3025	Availability of Trained person:	
		Adequacy of sample quantity	01
		Duration of testing/Time of Report release	12:50 pm

TEST PARAMETER

S. N.	Test Parameters	Method	Specification		Result	(Unit)
1	pH	IS 3025 (Part 11):2017	6.5-8.5	No Relaxation	7.640	-
2	Turbidity	IS 3025 (Part 10):2017	1.0	5.00	2.225	(NTU)*
3	TDS	IS 3025 (Part 16):2017	500	2000	405.1	(Mg/L)*
4	Chloride	IS 3025(Part 32): 2019	250	1000	160	(Mg/L)*
5	Total Alkalinity	IS 3025 (Part 23):1986	200	600	530	(Mg/L)*
6	Total Hardness	IS 3025 (Part 21):2019	200	600	480	(Mg/L)*
7	Colour	APHA 23 rd Edistion	5	15	12	Hazen
8	Taste	IS 3025 (Part 8) : 2017	Agreeable	Qualitative	Agreeable	Qualitative
9	Odour	IS 3025 (Part): 2018	Agreeable	Agreeable	Agreeable	Agreeable
10	Calcium as Ca	-	75	200	150	(Mg/L)
11	Magnesium as	-	30	100	83.67	(Mg/L)
Remark		"The Information regarding sample collected, submitted and Customer basic details provided by the customer itself."				

Reviewed By

1 Manoj

MANAGER

NIRMALA CONVENT SCHOOL
SHIKARPUR BYE PASS ROAD
BULANDSHAHR (U.P.)

Principal

Nirmala Convent School

Shikarpur By Pass Road

Bulandshahr (U.P.) 203001

End of Report

